

THIS ASSEMBLY SHALL BE INSPECTED BY THE TORRANCE MUNICIPAL WATER DEPARTMENT. AFTER WATER UTILITY'S APPROVAL, ASSEMBLY SHALL BE TESTED BY A CITY APPROVED TESTER CERTIFIED BY THE LOS ANGELES COUNTY DEPT. OF PUBLIC HEALTH. THE DEVELOPER/OWNER IS RESPONSIBLE FOR THE COST OF TESTING THE ASSEMBLY.

ITEM	DESCRIPTION	SIZE
1	D.I. WATER SERVICE (CLASS 350)	
2	90, D.I. ELBOW, MJ X FLG (UNI — FLANGE SHALL NOT BE USED)	SERVICE SIZE
3	D.I. SPOOL (BOTH ENDS SHALL BE FLANGED)	
4	90, D.I. ELBOW, FLG.	
(5)	DOUBLE CHECK VALVE	
6	3/4" COPPER BY-PASS ASSEMBLY (W/SCHLUMBERGER NEPTUNE T-10 METER CU.FT. REGISTER) 3-3/4" FIP BALL VALVE W/LOCKWING (JONES J1908, FORD B13-332W).	SL 3/4"
7	VALVE BOX ASSEMBLY PER T712	
8	MUELLER NO.2360-16 GATE VALVE, MJxFLG, W/EVERDUR STEM & SS 316 FASTENERS W/2" NUT & NRS OPENING CCW.	
9	M.J. x FLG. DUCTILE IRON TEE OR TAPPING SLEEVE (MULLER: H615, H616 OR H619)	

ENGINEERING DEPARTMENT

ACCOMPANYING STD'S T700, T701, T712, T713, T723 AND T116.

CITY OF TORRANCE

DATE ISSUED	DOUBLE CHECK - DETECTOR CHECK	STANDARD NO.
1 SEPT 2000	ASSEMBLY	T710-2
	RICHARD W. BURTT ENGINEERING DIRECTOR R.C.E. NO. 32862	SHEET 1 OF 1